

F-03 Practice Test Questions and Answers

1. What type of fire alarm system requires manual activation?

- A) Automatic detection system
- B) Manual pull station system
- C) Smoke detection system
- D) Heat detection system

2. Which NFPA standard covers fire alarm and signaling systems?

- A) NFPA 70
- B) NFPA 72
- C) NFPA 101
- D) NFPA 13

3. What is the maximum distance between manual pull stations in a corridor?

- A) 100 feet
- B) 150 feet
- C) 200 feet
- D) 250 feet

4. What voltage is typically used for fire alarm notification circuits?

- A) 12-24 VDC
- B) 120 VAC
- C) 240 VAC
- D) 480 VAC

Answers: 1-B 2-B 3-C 4-A

For More F-03 Questions and Answers FREE, F-03 Online Prep Training, F-03 Exam, F-03 Study Guide, F-03 Flashcards, F-03 Quizzes visit:

F-03 Practice Test