

# F89 Fire Protection Systems Practice Test Questions and Answers

**1. What is the primary purpose of a fire sprinkler system?**

- A) To prevent fires from starting
- B) To detect smoke and alert occupants
- C) To suppress or extinguish fires automatically
- D) To provide emergency lighting during fires

**2. At what temperature do standard fire sprinkler heads typically activate?**

- A) 135°F (57°C)
- B) 155°F (68°C)
- C) 175°F (79°C)
- D) 212°F (100°C)

**3. What type of fire suppression system is typically used in computer server rooms?**

- A) Water sprinkler system
- B) Foam suppression system
- C) Clean agent gas suppression system
- D) Dry chemical suppression system

**4. Which NFPA standard covers the installation of sprinkler systems?**

- A) NFPA 10
- B) NFPA 13
- C) NFPA 20
- D) NFPA 72

Answers: 1-C 2-B 3-C 4-B

For More F89 Fire Protection Systems Questions and Answers FREE, F89 Fire Protection Systems Online Prep Training, F89 Fire Protection Systems Exam, F89 Fire Protection Systems Study Guide, F89 Fire Protection Systems Flashcards, F89 Fire Protection Systems Quizzes visit:

**F89 Fire Protection Systems Practice Test**

Practice Test Geeks © All Rights Reserved